



Note 1: All coping cap joints must utilize a 6-inch concealed splice plate.

Note 2: All joints are to be sealed with an approved Duro-Last sealant on top of the splice plate, on both sides of the joint. Allow a 1/4-inch gap between coping sections.

Note 3: All cleats must be fastened 12-inches on center.

Note 4: All fasteners must penetrate into the nailer a minimum of 1 1/2-inches.

DATE: JANUARY 2009

PARAPET WALL DETAIL

DRAWN BY: ENG. DEPT.

FLAT COPING W/CONT. CLEAT

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF