



Note 1: All coping cap joints must utilize a 6-inch concealed splice plate.

Note 2: All joints are to be sealed with an approved Duro-Last sealant on top of the splice plate, on both sides of the joint. Leave a 1/4-inch min. gap between coping sections.

Note 3: All cleats must be fastened 12-inches on-center.

Note 4: All fasteners must penetrate into the wood nailer a min. of 1-1/2-inches.

DATE: JANUARY 2009

PARAPET WALL DETAIL

DRAWN BY: ENG. DEPT.

CANTED COPING W/CONT. BASE CLEAT

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF